

CITY OF PACIFIC GROVE

SEWER COLLECTION SYSTEM CIPS 3, 4, 5, AND 8 IMPROVEMENTS PROJECT

NOTICE TO CONTRACTORS:

Bid Opening Date: April 10, 2020 at 2:00 PM

ADDENDUM NO. 2

The following changes are hereby made to the project plans, specifications, and contract documents:

- (1) **High Density Polyethylene Pipe:** To Section 33 11 00.19-3, modify paragraph 2.01.A.2 to read:

“New 18” HDPE Pipe Installed by Pipe Bursting: Pipe interior diameter shall be 17.0 inches or greater; if pipe **inside** diameter based on Contractor recommended DR results in a diameter less than 17.0 inches, provide HDPE pipe of sufficient nominal diameter to achieve the minimum 17.0 inch inside diameter at no additional cost to City.”

Bidder shall sign, date, and include Addendum No. 1 in the bid proposal.

by: _____
Bidder

_____ Date